

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-1328:100 Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Air Balance, 7301 International Drive, Holland Ohio 43528  
Contact: Chuck Schneider (419) 865-5000 \*FAX (419) 865-1375

**DESIGN:** FIRE SEAL Models 119V, 119H, D19H and D19V series with suffixes L, M or X. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, rating and UL or CSFM label.

**APPROVAL:** Listed as 1½-hour fire-rated damper for vertical and horizontal application.

**NOTE:**

1. Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.
2. Formerly 3225-0206:014

\*Rev. 06-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**